



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

DT 08-02-2021

CORRIGENDUM

NIT No : 01 /SEE/EC-II/BTCL/CH/20-21

Name of work: - Providing EI & Fans, AC units, AFD System for the proposed Office of CCI in Ground Floor at TE Mambalam, Chennai. **(SW: SITC of 11nos of split type AC units)**

Sl. No.	Reference	NIT Pg. No.	Existing Clause	To be read as
1.	Clause 5	19	The agency should offer proto type unit for inspection/testing at factory within 10 days from the date of award letter. However, in case of a proto type approval (issued not more than 6 months prior to the date of award of this tender) from BTCL for the same specification is available, the same shall be considered valid with regard to this tender also.	The agency shall furnish factory test certificate for AC unit of same model proposed to be supplied
2.	Clause 9	21	Type Test Certificate for two samples of each type/ model of air conditioners from any NABL / ILAC Accredited lab shall be submitted by the firm. The type test results shall include capacity test at standard rating test conditions and maximum operating test as specified in IS:1391(Part-2)-1992.	The agency shall furnish factory test certificate for AC unit of same model proposed to be supplied

All other terms and conditions remains unaltered

Executive Engineer(E),
BSNL/BTCL Electrical Division III
No.22, Kellys TE Bldg, Kellys,
Chennai- 600 010.
Phone:- 044-26478616