

Bharat Sanchar Nigam Limited

(Electrical Wing)

Office of

Executive Engineer (E)
BSNL Electrical Division I,
Second Floor, Kellys Telephone Exchange
Kellys, Chennai-10
Ph.No.044-26448484

SHORT NOTICE INVITING TENDER

TENDER DOCUMENT

Name of the work :- Shifting and re-Installation of the 3 Nos of PAC units for OCB/NIB at 1st floor of TE KK Nagar Bldg, Chennai. (From Chrompet).

NIT No.: 12/EEE/ED-I/BSNL/CH/24-25

This tender document contains	33 (Inirty three)) pages only
-------------------------------	---------------------	--------------

(To be filled in by the Contractor)

Name of the Agency	
Address	
Telephone No. of agency:	
E_mail ID of agency:	

Contractor Page 1 of 34 Executive Engineer

INDEX

SL. No	Description	Page no.
1	Front cover and Index	2
2	Notice Inviting Tender form - BSNL EW6	6
3	General Instructions to the Bidders	10
4	Undertaking to abide by EW 6 & EW 8 (Form 'A')	12
5	Undertaking regarding EPF& ESI provisions (Form 'B')	13
6	Performance report of works (Form 'C')	14
7	No Near relative working certificate (Form 'D')	15
8	Model form of Bank Guarantee for EMD (Annexure-I)	16
9	Model form of Performance security Guarantee bond (Annexure-II)	17
10	Schedule of Quantities	19
11	Specifications	22
12	List of Approved Makes	28
13	List of Indian Standards	30
14	Proforma Schedules	31
15	BSNL EW – 8 form	32

Contractor Page 2 of 34 Executive Engineer

INFORMATION AND INSTRUCTIONS FOR BIDDERS

The Executive Engineer (Elect), BSNL, ED-I, Chennai on behalf of the CMD,BSNL invites Item rate bids from eligible bidders in Single bid system for the following work:

1	Name of work	Shifting and re-Installation of the 3 Nos of PAC units for OCB/NIB at 1st floor of TE KK Nagar Bldg, Chennai. (From Chrompet).
2	Estimated cost put to tender	Rs. 1,10,191/-
3	Earnest Money	Rs. 2,204/-
4	Period of completion	ONE Month
5	Tender Fee(Non-	
	refundable)	Rs.500 (+) 18% GST=Rs 590/-
6	Last date & time for	
	submission of tender	Up to 15:00 Hrs. on 11-06-2024
7	Date and time for	
	opening of tender	15:30 Hrs. on 11-06-2024

Contractor Page 3 of 34 Executive Engineer

ELIGIBILITY CRITERIA

The bidders satisfying the following conditions:

ELIGIBILITY CRITERIA

(a) Financial Norms:

Average annual turnover during the last 3 years, ending 31st March of the previous financial year, should be at least 30% of the estimated cost put to tender.

AND

(b) Physical Norms:

BSNL enlisted contractors in Electrical category of respective class as per their tendering limits.

OR

Experience of having successfully completed similar works in BSNL during last 7 years ending last day of the month previous to the one in which applications are invited should be either of the following:-

Three similar successfully completed works costing not less than the amount equal to 40% of the estimated cost put to tender.

(OR)

> Two similar successfully completed works costing not less than the amount equal to 60% of the estimated cost put to tender.

(OR)

➤ One similar successfully completed work costing not less than the amount equal to 80% of the estimated cost put to tender.

For the purpose of this clause "similar works" means "Supply/ITC/Annual Maintenance Contract of HPAC/PAC UNITS – REPAIRING/SERVICING OF UNITS"

The experience certificate/Completion Certificate shall be issued by an officer not below the rank of Executive Engineer / Assistant General Manager.

Contractor Page 4 of 34 Executive Engineer

IMPORTANT INSTRUCTIONS TO BIDDERS DOWN LOADING THE TENDER DOCUMENT FROM WEB SITE

The bidders, who have down loaded the tenders from the web site, shall read the following important instructions carefully before quoting the rates and submitting the tender documents.

- 1. The tenderer should see carefully and ensure that the tender document containing all the pages as per the index has been down loaded for making required entries. The balance pages of Standard BSNL EW8 form will be attached with the agreement after the award of work.
- 2. A clear print out of tender document shall be taken on good quality A4 size paper and the printer settings, etc., shall be such that the document is printed as appearing in the web and without any change in format, number of pages, etc., and shall also ensure that no page is missing. Only original computer printout of the document shall be used. Photocopy shall not be accepted.
- 3. In case of any doubt in the downloaded tender, the same shall be got clarified from the Engineer in charge calling the NIT before submission.
- 4. The name of the bidder shall be filled on the relevant pages of tender document and all the pages shall be invariably signed. (With stamp)
- 5. The tenderer shall ensure that the downloaded tender document is properly stitched before submitting the document.
- 6. There shall be no correction / addition / alteration / omission made in the text of the downloaded tender document. If found otherwise, the same shall be treated as non-responsive and rejected.
- 7. The tenderer shall sign the declaration enclosed before submitting the tender.
- 8. The tenderer shall submit the tenders in 2 covers marked as No.1 and No.2. The tenderer shall submit the credentials for meeting the eligibility conditions along with the cost of the tender fee and EMD in the prescribed format as detailed in NIT, along with a covering letter on his printed letter head stating the details of enclosures in the first cover. The credentials shall be self-attested. The second cover shall contain the price bid. The rates and amounts should be filled in the schedule of work attached thereto.
- 9. The **cover-1** shall contain the following.
 - a. Tender Fee in the prescribed format
 - b. EMD in the prescribed format
 - c. Certificate of Financial Turnover from Chartered Accountant if applicable
 - d. Documents fulfilling Eligibility criteria (Please note that in case the bidder is authorised by the manufacturer, the original authorisation letter is to be scanned and uploaded)
 - e. Enlistment certificate issued by BSNL if applicable
 - f. Electrical license issued by TN Govt.
 - g. GST Registration Number details
 - h. PAN Card
 - i. EPF and ESI Registration certificate, if applicable
 - j. Certificate of work experience issued by client department (Form 'C') if applicable

Not submitting the above documents in Cover-1, the Cover-2 will not opened

10. The Cover-1 and 2 shall be deposited in the tender box available in the office of tender opening authority, by all the bidders before 3:00 PM on 11-06-2024 the tender opening date, failing which the tender shall not be opened.

Contractor Page 5 of 34 Executive Engineer

BSNL EW-6 Bharat Sanchar Nigam Limited

Electrical Wing

SHORT NOTICE INVITING TENDER

Electrical Division: **ED-I, Chennai** Sub Division: **ESD-III, Chennai**

NIT No.: 12/EEE/ED-I/BSNL/CH/24-25 dtd 28/05/2024

Item rate tenders on single bid system are invited on behalf of CMD,BSNL for the work "Shifting and re-Installation of the 3 Nos of PAC units for OCB/NIB at 1st floor of TE KK Nagar Bldg, Chennai. (From Chrompet)." from the eligible bidders as per NIT notification. The enlistment of the bidders should be valid on the opening date of tender. In case the date of opening of tender is extended, the enlistment of bidder should be valid on the original date of opening of tender.

- Tenders which should always be placed in sealed covers with the name of the work written on the envelope will be received and opened by the tender opening authority as per the date and time mentioned in INFORMATION AND INSTRUCTIONS FOR BIDDERS. Unsealed tenders will be summarily rejected.
- 2. Intending bidder is eligible to submit the bid provided that he has definite proof from the appropriate authority, which shall be to the satisfaction of the competent authority as per the eligibility conditions mentioned in the NIT notification page.
- 3. The work is estimated to cost **Rs 1,10,191/-** This estimate, however, is given merely as a rough guide.
- 4. Agreement shall be drawn with the successful bidder on prescribed form as amended up to the date of opening of tender. Bidder shall quote his rates as per various terms and conditions of the said form which will form part of the agreement.
- 5. The time allowed for carrying out the work will be **ONE Month** from the 10th day after the date of written order to commence the work.
- 6. The site for the work is available / or the site for the works shall be made available in parts. The successful bidder shall execute the work in coordination with other agencies working in the campus.
- 7. The bid documents consisting of plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents can be seen and downloaded from website www.chennai.bsnl.co.in at free of cost. The BSNL EW-8 document can be seen from the web site www.chennai.bsnl.co.in atfree of cost.
- 8. The Tender Fee in the form of Demand Draft issued by the Nationalized / Scheduled bank authorized by the Reserve Bank of India, drawn in favour of **BSNL**, **Chennai Telephones** payable at **Chennai.** The validity of the tender cost in the form of DD shall be **60 days** from the date of opening.
- 9. The Earnest money deposit (EMD) in the form of Demand Draft / FDR / BG (BG is only for Air Conditioning, Diesel Engine Alternator, Lifts, and Sub Station works wherever the amount of EMD is more than Rs.20,000)/ CDR of a nationalized / scheduled bank authorized by the Reserve Bank of India, drawn in favour of BSNL, Chennai Telephones payable at Chennai. The validity of the EMD in the form of DD shall be 60 days from the date of opening. If the EMD is in the form of CDR/FDR/BG, the validity shall be 180 days from the date of opening. In case of L1 bidder, the validity of CDR/FDR/BG is to be extended up to the observation period as that of the Performance guarantee / Security deposit. Exemption from payment of Tender Fee, Earnest Money and Security Deposit by any other unit/ department shall not hold good for BSNL.

Contractor Page 6 of 34 Executive Engineer

- 10. The last date for submission of bid is **11-06-2024 up to 3:00 PM** and the bid submitted shall be opened at 03:30 PM on the day. If a holiday is declared on the tender opening day, the tender will be opened on the next working day.
- 11. **Performance Guarantee**: The bidder is required to furnish Performance guarantee for an amount equal to 5% of the contract value in the form of bank guarantee/CDR/FDR/DD (of a Nationalized/ Scheduled Bank in a standard format) within two weeks from the date of issue of acceptance letter. This period can be further extended by the Engineer-incharge up to a maximum period of two weeks on written request of Bidder. The validity period of the performance security in the form of performance bank guarantee shall be: ONE Month from the date of actual completion of work, for AMC works; and One year from the date of actual completion of work for all other works. **In case the bidder fails to deposit the said performance guarantee within the stipulated period, including the extended period if any, the Earnest Money deposited by the bidder shall be forfeited automatically without any notice to the bidder and the bidder will not be allowed to participate in the re tendering for the same work.**
- 12. **Security Deposit**: In addition to Performance guarantee stated above, a sum @ 10% of the gross amount of the bill shall be deducted from each running bill of the contractor till the sum be deducted with the sum already deposited as earnest money, will amount to security deposit of 5% of the contract value of the work. **The security deposit shall be released after an observation period as follows: Three Months from the date of actual completion of work, for AMC works; and One year from the date of actual completion of work for all other works.**
- 13. If it is found at any stage of tender scrutiny after submission of tender that the bidder has made any correction/addition/alteration/omission intender documents vis-à-vis tender documents available on the website /original Draft NIT in office, the bid shall be treated as non-responsive and shall be summarily rejected and the BSNL shall, without prejudice to any other right or remedy, be at liberty to forfeit 50% of the said earnest money as aforesaid. Further, the bidder shall not be allowed to participate in the retendering process of the work.
- 14. The Tender documents shall not be sent through the Courier/Post. Tender documents received through Courier/post shall not be opened / considered at all. All communication with the bidders shall be in writing. Fax / E-mail shall be covered under this category and considered as adequate means of communication.
- 15. Intending bidders are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their tenders, the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their tender. A bidder shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charge consequent on any misunderstanding or otherwise shall be allowed. The bidder shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the
- 16. contract documents. Submission of a tender by a bidder implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work to be done and of conditions and rates at which stores, tools and plant, etc. will be issued to him by the BSNL and local conditions and other factors having a bearing on the execution of the work.

Contractor Page 7 of 34 Executive Engineer

- 17. The competent authority on behalf of the CMD does not bind himself to accept the lowest or any other tender and reserves to himself the authority to reject any or all the tenders received without the assignment of any reason. All tenders in which any of the prescribed condition is not fulfilled or any condition including that of conditional rebate is put forth by the bidder shall be summarily rejected. The competent authority on behalf of CMD reserves to himself the right of accepting the whole or any part of the tender and the bidder shall be bound to perform the same at the rate quoted.
- 18. Canvassing whether directly or indirectly, in connection with tenders is strictly prohibited and the tenders submitted by the bidders who resort to canvassing will be liable to rejection.
- 19. Agreement shall be drawn with the successful bidder on prescribed form. Bidder shall quote his rates as per various terms and conditions of the said form, which will form part of the agreement.
- 20. The bidder should give a certificate as per the following that none of his/her relative is employed in BSNL units as per **Form 'D'**. In case of proprietorship firm, certificate will be given by the proprietor and for partnership firm certificate will be given by all the Directors of the company.
 - a. Near relatives of all BSNL employees either directly recruited or on deputation are prohibited from participation in tenders and execution of works in the different units of BSNL. The near relatives for this purpose are defined as:
 - i. Members of a Hindu Undivided family.
 - ii. They are husband and wife.
 - iii. The one is related to the other in the manner as father, mother, son(s) & son's wife(daughter-in-law), Daughter(s) & daughter's husband(son-in-law), brother(s) & brother's wife, sister(s) & sister's husband(brother -in-law).
 - b. The company or firm or any other person is not permitted to tender for works in BSNL unit in which his near relative(s) is(are) posted. The unit is defined as SSA/Circle/Chief Engineer/Chief Archt./Corporate office for non-executive employees and all SSA in a circle including circle office/Chief Eng./Chief Archt./Corporate office for executive employees (including those called as Gazetted officers at present). The bidder should give a certificate that none of his/her such near relative is working in the units as defined above where he is going to apply for tender/work, for proprietorship, partnership firms and limited company certificate shall be given by the authorized signatory of the firm. Any breach of these conditions by the company or firm or any other person, the tender/work will be cancelled and earnest money/performance guarantee will be forfeited at any stage whenever it is so noticed. BSNL will not pay any damages to the company or firm or the concerned person. The company or firm or the person will also be debarred for further participation in the concerned unit.
 - c. No employee in BSNL/ Govt. of India is allowed to work as a contractor for a period of two years of his retirement from service without the prior permission. The contract is liable to be cancelled if either the bidder or any of his employees is found at any time to be such a person who had not obtained the permission as aforesaid before submission of tender and engagement in the bidders service.

Contractor Page 8 of 34 Executive Engineer

- 21. The tender for the work shall remain open for acceptance for a period of ninety (90) days from the date of opening of tenders. If any bidder withdraws his tender before the said period or issue of letter of acceptance, whichever is earlier, or makes any modifications in the terms and conditions of the tender which are not acceptable to the BSNL, then the BSNL shall, without prejudice to any other right or remedy, be at liberty to forfeit 50% of the said earnest money as aforesaid. Further the tenderer shall not be allowed to participate in the retendering process of the work.
- 22. The bidder has to comply with the provisions of EPF and miscellaneous provisions Act-1952 and employees provident fund scheme-1952 as amended up to date in respect of labours/employees engaged by them for this work. Any consequence arising due to non-complying of provisions as specified above shall be the sole responsibility of the firm only. The agency shall give an undertaking to this effect as per **Form 'B'**.
- 23. Extension of Validity of tender: In case, where the letter of award of work cannot be placed within the validity period of the tender, the BSNL can request the bidder to extend the validity of their respective tenders and the Earnest Money deposit by a reasonable period. In such cases, extension of validity of Earnest Money deposit by 30 days beyond the extended validity date of tender should also be asked for. While BSNL can make the request for extension, the tenderer is free to either extend the validity or refuse the request to extend the validity.
- 24. Rates quoted by the contractor shall be firm and shall be valid for the currency of contract. No cost escalation shall be permitted during the currency of contract.
- 25. This notice inviting tender shall form a part of the contract document. The successful bidder, on acceptance of his tender by the Accepting Authority shall within 15 days from the stipulated date of start of the work, sign the contract consisting of:
 - a. The Notice Inviting Tender, all the documents including additional conditions, specifications and drawings, if any, forming part of the tender as uploaded at the time of invitation of tender, subsequent amendments issued and the rates quoted at the time of submission of bid and acceptance thereof together with any correspondence leading thereto.
 - b. Standard BSNL EW-8 form

Contractor Page 9 of 34 Executive Engineer

General Instructions to the Bidders

- The intending bidder must read the terms and conditions of BSNL-EW 6 carefully. He should only submit his bid, if he considers himself eligible and he is in possession of all the documents required.
- 2. Information and instructions for bidders posted on website shall form part of bid document.
- 3. Applicants are advised to keep visiting the above mentioned website from time to time (till the deadline for bid submission) for any updates in respect of the tender documents, if any. Failure to do so shall not absolve the applicant of his liabilities to submit the applications complete in all respect including updates thereof, if any. An incomplete application may be liable for rejection.
- 4. Even though any bidder may satisfy the above requirements, he would be liable to disqualification if he has:
- a. Made misleading or false representation or deliberately suppressed the information in the forms, statements and enclosures required in the eligibility criteria document.
- b. Record of poor performance such as abandoning work, not properly completing the contract, or financial failures / weaknesses etc.
- 5. If any information furnished by the bidder is found incorrect at a later stage, he shall be liable to be debarred from tendering/taking up of works in BSNL. The BSNL reserves the right to verify the particulars furnished by the applicant independently.
- 6. GST and any other tax applicable in respect of this contract shall be borne by the bidder himself. The bidder shall quote his rates considering all such taxes. The TDS as per the Govt. regulations will be recovered from the contractor.

7. **Tender Evaluation**:

- (a) The evaluation and comparison of responsive bids shall be done on the basis of Net cost to BSNL on the prices offered inclusive of packing, forwarding, freight and insurance charges etc., but excluding GST. The bid with lowest net cost as elaborated above will be the L1 bidder.
- (b) Vendors should furnish the correct GST Rate in the price schedule. If the Input Tax Credit is found to be not admissible at any stage subsequently owing to wrong furnishing of GST Rate, then the vendors will be liable to refund such non-admissible amount, if already paid, along with penalty if charged by the concerned authority.
- 8. However, pursuant to the constitution (Forty-sixth amendment) act, 1982, if any further tax or levy is imposed by statute, after the last date of receipt of tenders, and the contractors there upon necessarily and properly pays such taxes/ levies, the contractor shall be reimbursed the amount so paid, provided such payment, if any, is not in the opinion of Superintending engineer (whose decision shall be final and binding) be attributable to delay in execution of work within the control of contractor.
- 9. The Contractor shall, within a period of 30 days of imposition of any further tax or levyin pursuant to the constitution of (Forty sixth amendment) act 1982 give a written notice thereof to the Engineer-in-charge that the same is given pursuant to this condition, together with all necessary information relating thereto.

10. Bye laws Indemnity against liabilities:

(a) The bidder shall comply with all bylaws and regulations of the local and statutory authorities having jurisdiction over the works and shall be responsible for payment of all fees and other charges and giving and receiving all necessary notices and keep the Engineer –in-charge informed about the notices issued and received.

Contractor Page 10 of 34 Executive Engineer

- (b) The bidder shall indemnify the department against all claims in respect of patent rights design, trademark or name of other protected rights in respect of any plant, machine, work or materials used for or in connection with the works or temporary works and from and against all claims demands, proceedings, costs, charges and expenses whatsoever in respect of or in relation thereto.
- (c) The bidder shall defend all actions arising from such claims and shall himself pay all royalties, License fees, damages, costs and charges of all and every sort that may be legally incurred in respect hereof shall be borne by the bidder.
- (d) All liabilities / penal recoveries on matters arising out of tax /levies such as incorrect deductions, discrepancies in the filing of returns, revised assessments by the concerned authorities etc., shall be borne by the bidder.

11. Termination of contract on death of contractor:

Without prejudice of any of the rights or remedies under this contract, if the contractor dies, the Engineer in charge on behalf of the BSNL shall have the option of terminating the contract without compensation to the contractor.

- 12. Indulging of contractor in criminal /antisocial activities and cases under investigation/charge sheeted by CBI or any other government agencies etc. :If the CBI/Independent External Monitor (IEM) /Income tax/ Sales Tax /GST/ Central Excise/Custom Departments recommend such a course Action will be taken as per the directions of CBI or concerned department.
- 13. As a general notion, the terms and conditions/instructions contained in various pages of this document are addressed assuming the bidder as 'Male'. However, the same shall remain and assumed to be addressed in case of 'Female' bidder also, except for the gender centric words, which shall be 'female' centric at appropriate places.

Contractor Page 11 of 34 Executive Engineer

FORM 'A'

Undertaking to abide by EW 6 & EW 8

	son / Daughter of ident of
hereby give an undertaking	that I have read the complete bid document and I am aware of SSNL EW 6 & 8 forms and I confirm that I will abide by all the
terms and conditions available in BSN	NL EW 6 & 8 forms.
(Seal of the firm)	(Signature of Bidder)

Contractor Page 12 of 34 Executive Engineer

FORM 'B'

Undertaking regarding EPF provisions

"IResident ofhereby give an undertaking that
* I/We have employed only persons in our establishment and hence the EPF and Miscellaneous provisions Act, 1952 is not applicable to my / our establishment.
* I / We have registered as per the EPF and Miscellaneous provisions Act, 1952 and our registration no ** is We undertake to keep it valid during the currency of contract.
In case at any stage, it is found that the information given by me is false / incorrect, BSNI shall have the absolute right to take any action as deemed fit/without any prior intimation to me".
* strike out whichever is not applicable
**Attach a self-attested photo copy of the above said EPF registration certificate.
(Seal of the firm) (Signature of Bidder)
Undertaking regarding ESI provisions
"IResident ofhereby give ar undertaking that
st I / We have employed only persons in our establishment and hence the ESI and Miscellaneous provisions Act,1948 is not applicable to my / our establishment.
* I / We have registered as per the ESI and Miscellaneous provisions Act, 1948 and our registration no.** is We undertake to keep it valid during the currency of contract.
In case at any stage, it is found that the information given by me is false / incorrect, BSNI shall have the absolute right to take any action as deemed fit/without any prior intimation to me".
* strike out whichever is not applicable
**Attach a self-attested photo copy of the above said ESI registration certificate.
(Seal of the firm) (Signature of Bidder)

Contractor Page 13 of 34 Executive Engineer

FORM 'C'

Executive Engineer or Equivalent

Performance report of works

1.	Name of Agency
2.	Name of work
3.	Agreement no.
4.	Final Value of Work Done
5.	Date of start of work
6.	Actual date of completion
7.	Performance: Satisfactory / Not Satisfactory

Dated:

Contractor Page 14 of 34 Executive Engineer

						FORM '	D'
	No Ne	ar relative	<u>workir</u>	ng certifica	<u>ate</u>		
I	Son /	Daughter	of	Shri			Resident
of hereby	certify th	at none of	my rela	ative(s) as	defined	d in the tende	r document
is/are employed in BSNL	unit as p	er details gi	ven in t	ender docu	ıment.	In case at any	stage, it is
found that the information	given by r	me is false/i	ncorrec	t, BSNL sha	all have	the absolute ri	ght to take
any action as deemed fit/w	ithout any	prior intimat	tion to r	me.			

(Signature of Bidder)

(Seal of the firm)

Contractor Page 15 of 34 Executive Engineer

Annexure I MODEL FORM OF BANK GUARANTEE FOR EMD

(For submitting EMD for Air Conditioning, Diesel Engine Alternator, Lifts, and Sub Station Works wherever the amount of EMD is more than Rs.20,000/-)

Whe	reas				(hereinaft	er called	"the	bidder(s)") has submitted
its T	ender dat	ed	for the	work				. , ,
			- 					KNOW ALL MEN
by	these	presents	that	WE				OF
		•	having	g our	registered	office	at	
(her	einafter c	alled "the Ba	nk") are	bound i	unto			(hereinafter called
								ill and truly to be made of
the s	said BSNL	, the Bank bi	nds itself	, its succ	cessors and a	assians b	v the	se presents.

THE CONDITIONS of the obligation are:

- 1. If the Bidder(s) withdraws its Tender during the period of Tender validity specified on the Tender Form: or
- 2. If the Bidder(s) having been notified of the acceptance of its Tender by the BSNL during the period of Tender validity.
 - (a) Fails or refuses to execute the Contract.
 - (b) Fails or refuses to furnish security Deposit in accordance with the conditions of Tender document.

We undertake to pay to the BSNL up to the above amount upon receipt of its first written demand, without the BSNL having to substantiate its demand, provided that in its demand, the BSNL will note that the amount claimed by it is due to it owing to the occurrence of one or both of the two conditions, specifying the occurred condition or conditions.

This guarantee will remain in force as specified in the Tender Document up to and including Thirty (30) days after the period of the Tender validity and any demand in respect thereof should reach the Bank not later than the specified date/dates.

Signature of the Bank

Signature of the Witness Name of Witness

Address of Witness:

Contractor Page 16 of 34 Executive Engineer

ANNEXURE II PERFORMANCE SECURITY GUARANTEE BOND

1.	In consideration of the CMD, BSNL (hereinafter called 'BSNL') having agreed to exempt (hereinafter called 'the said bidder(s)') from the demand under
	the terms and conditions of an agreement/Advance Purchase Order No dated made between and
	for the supply of (hereinafter called
	for the supply of (hereinafter called "the said agreement"), of security deposit for the due fulfilment by the said bidder (s)
	of the terms and conditions contained in the said Agreement, on production of the bank
	guarantee forwe, (name of the bank) (hereinafter refer to as "the bank") at the request of
	(hereinafter refer to as "the bank") at the request of
	(bidder(s)) do hereby undertake to pay to
	the BSNL an amount not exceeding against any loss or damage caused to or suffered or would be caused to or suffered by BSNL by reason of any
	breach by the said Bidder(s) of any of the terms or conditions contained in the said
	Agreement.
2.	We (name of the bank) do hereby undertake to pay the
	amounts due and payable under this guarantee without any demur, merely on a
	demand from the BSNL by reason of breach by the said bidder(s)' of any of the terms or
	conditions contained in the said Agreement or by reason of the bidders(s)' failure to perform the said Agreement. Any such demand made on the bank shall be conclusive as
	regards the amount due and payable by the Bank under this guarantee where the
	decision of BSNL in these counts shall be final and binding on the bank. However, our
	liability under this guarantee shall be restricted to an amount not exceeding
	,
3.	We undertake to pay to the BSNL any money so demanded notwithstanding any dispute
	or disputes raised by the bidder(s)/supplier(s) in any suit or proceeding pending before
	any court or tribunal relating thereto our liability under this present being absolute and unequivocal. The payment so made by us under this bond shall be valid discharge of our
	liability for payment there under and the bidder(s)/supplier(s) shall have no claim
	against us for making such payment.
4.	We (name of the bank) further agree that the guarantee
	herein contained shall remain in full force and effect during the period that would be
	taken for the performance of the said agreement and that it shall continue to be
	enforceable till all the dues of the BSNL under or by virtue of the said Agreement have
	been fully paid and its claims satisfied or discharged or till (office/BSNL) BSNL certifies that the terms and conditions of the said Agreement have
	been fully or properly carried out by the said bidder(s) and accordingly discharges this
	guarantee. Unless a demand or claim under this guarantee is made on us in writing on
	or before the expiry of TWO/TWO AND HALF/THREE YEARS (as specified in P.O) from
	the date hereof, we shall be discharged from all liabilities under this guarantee
	thereafter.
_	
5.	We (name of the bank) further agree with the BSNL that the BSNL shall have the fullest liberty without our consent and without affecting in any
	manner our obligations hereunder to vary any of the terms and conditions of the said
	Agreement or to extend time of performance by the said bidder(s) from time to time or
	to postpone for any time or from time to time any of the powers exercisable by the
	BSNL against the said Bidder(s) and to forbear or enforce any of the terms and
	conditions relating to the said agreement and we shall not be relieved from our liability
	by reason of any such variation, or extension being granted to the said Bidder(s) or for

Contractor Page 17 of 34 Executive Engineer

any forbearance, act or omission on the part of the BSNL or any indulgence by the BSNL to the said Bidder(s) or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.

6.	This guarantee will not be discharged due to the or the Bidder(s)/supplier(s).	change in the constitution of the Bank
7.	We (name of the bank) guarantee during its currency except with the pre-	
	Dated the day of	
	for	(indicate the name of bank)

Contractor Page 18 of 34 Executive Engineer

SI. no	Description of Item	Qty & Unit	Rate / Unit Excluding GST	Total Amount Excluding GST	% TS90	CGST Amount in Rs.	% TS9S	SGST Amount in Rs.	% LSDI	IGST Amount in Rs.	Total Amount including GST
1	2	3	4	5	6	7	8	9	10	11	12
1	Dismantling and Shifting of existing of 7TR conventional type PAC units from OCB Exchange PAC plant to Transmission Exch PAC plant at 1st floor including all accessories, cables, refrigerant pipes, indoor unit supports, refrigerant pipe supports, indoor & outdoor units, and all accessories loading & unloading at both ends i/c positioning of indoor unit and keeping other items at I floor of KKN etc complete as required	2 Jobs									
2	Laying of dismantled trays for refrigerant pipe lines / cables made of MS members along with supports i/c all accessories etc complete as required	20 mtrs									
		-									
3	Laying of the recovered refrigerant pipe lines of size for hot and cold circuits, leak and pressure testing of refrigerant lines, vaccumising, insulation of refrigerant piping arrangement, welding etc, complete as per specifications (Hot Gas Line, 7/8" dia. and Liquid Line, 5/8" dia.)	30 mtrs									
					•		•		•		
4	Laying of recovered 4 core 2.5 Sqmm PVC insulated PVC sheathed copper conductor armoured UG cable including cable gland end termination etc as required	30 mtrs									

Contractor Page 19 of 34 Executive Engineer

1	2	3	4	5	6	7	8	9	10	11	12
5	Pressure testing of existing 7TR precision type PAC unit by complete purging of refrigerant system, vaccumizing the system, & exposing to appropriate pressure with Nitogen gas on both suction and discharge sides of compressor for 48hours, checking the system for for any leakage, arresting the leakage by necessary bracing,										
	vaccumizing etc as reqd.(Note: Warranty for 6months shall be extended for welding / bracing undertook by the agency for this item)	2 Jobs									
6	Supplying and charging of R407C/R22 Refrigerant gas for the existing 7 TR Precision Package AC Unit etc. as required.	40 Kgs									
7	Replacement of following items with new one in the existing Sidwal make 7 TR Precision Package AC Unit etc. as required.	2 -									
а	Liquid line drier	nos									
b	7/8" Ball valve	1No									
С	5/8" Ball Valve	1No									
8	Supplying and laying following sizes of PVC insulated PVC sheathed armoured U/G cable of 1.1KV grade, conforming to relevant IS on the wall/existing trench, existing cable trays i/c interconnections, end termination, gland earthing for extending power supply to PAc units complete etc. as required	40									
а	4 Core 2.5 Sqmm Copper conductor Cable	mtrs									
	Providing and fixing GI ducting made of 24 Gauge GI sheet including										
9	necessary supports and frame work suitable for 7TR PAC units complete as required.	30 Sqm									
	Total Net cost	(excl. G	SST) Rs.				Тс	tal cost	(Incl. G	ST) Rs.	

Total Net cost (excl. GST) in words Rupees

CONTRACTOR EE(E), ED-1

Contractor Page 20 of 34 Executive Engineer

IMPORTANT NOTES:-

1	The firm shall be responsible to ensure that GST shown in the above columns is correct & Input Tax Credit for the amount shown above is admissible as per GST Act as amended up to date".
2	Invoice /Bill should be pre-printed as per the GST format.
3	The evaluation and comparison of responsive bids shall be done on the basis of Net cost to BSNL on the prices offered inclusive of packing, forwarding, freight and insurance charges etc., but excluding GST
4	The rates for all items of work shall, unless clearly specified otherwise, include cost of all labour, materials and other inputs involved in the execution of the terms as specified in the scope of work.
5	No advance payments can be made. Stipulations like levy of interest if payment is not made in a specified time are also not acceptable and the payment is governed by the normal BSNL practice.

Contractor Page 21 of 34 Executive Engineer

TECHNICAL SPECIFICATIONS

- 1. The work is to be carried out as per CPWD specifications (Internal/External) and I.E. Rule amended from time to time & Indian Electricity Rules as amended up to date.
- 2. Good workmanship is an essential requirement to be complied with. The entire work of Manufacture, Fabrication, assembly and installation shall conform to sound engineering practice. Rates quoted shall be inclusive of packing, forwarding, insurance, freight and delivery at site Watched ward of all materials.
- 3. All sundry fittings, assemblies, accessories, hardware items, foundation bolts, termination lugs for electrical connection as required and all other sundry items which are useful & necessary for proper assembly and efficient working of the various components of the works shall be deemed to have been included in the tender.
- 4. Following works shall be carried out by the contractor and therefore their cost shall be deemed to be included in their tendered cost.
 - a) The contractor shall be responsible for repairing all damages and restoring the same to their original finish. He shall also remove at his cost all unwanted and waste materials arising out of his work from his site.
 - b) All chases required in connection with the electrical works shall be provided and filled by the Contractor to the original finish.
 - c) Temporary shed if required over the storage space and locking arrangement, watch and ward of the materials shall be provided by firm till completion of the work and final taking over of the installation by the department.
- 5. The contractor shall employ qualified engineer / supervisor as required and intimate names of Such Persons to the Engineer-in-charge on commencement of work. Failure to employ will attract penalty as per agreement.
- 6. Termination of all connections on main board, sub main board & distribution boards will be done by Crimping method & nothing extra will be paid on this account.
- 7. Numbering and sign writing of the entire installation shall be carried out by the contractor as per Instructions of the Engineer-in-charge for which nothing extra shall be paid.
 - a) On completion of installation following tests shall be carried out.
 - b) Polarity test
 - c) Earth continuity test
- 8. On completion of installation a certificate shall be furnished by the contractor in prescribed Performa, this certificate shall be in addition to the certificate required by local electric Supply Company.

Contractor Page 22 of 34 Executive Engineer

SPECIAL CONDITIONS

1.0 General

1.1 Except for the items, for which Particular Specifications are given or where it is specifically mentioned otherwise in the description of the items in the schedule of quantities, the work shall generally be carried out in accordance with the "CPWD Specifications 2019 Vol-I&II" with upto date correction slips and as per instructions of Engineer-in-Charge. Wherever CPWD Specifications are silent, the latest IS Codes / Specifications shall be followed and the rates should be all inclusive.

In the case of discrepancy between the Schedule of Quantities, the Specifications and/ or the Drawings, the following order of preference shall be observed:-

- a. Nomenclature of item as per Schedule of Quantities
- b. Special Conditions.
- c. Particular Specifications.
- d. Drawings and specification mentioned in the tender document.
- e. CPWD Specifications-2019 (Vol.-1 & 11) with upto date correction slips.
- f. Indian Standard Specifications
- g. Manufactures Specifications.
- h. Sound Engineering Practice as per the decision of Engineer-in-Charge.
- 1.2 Any reference made to any Indian Standard Specifications, shall imply to the latest version of that standard, including such revisions / amendments as issued by the Bureau of Indian Standards upto last date of receipt of tenders.
- 1.3 The work shall be executed and measured as per metric dimensions given in the Schedule of Quantities, drawings etc. (FPS units wherever indicated are for guidelines only).
- 1.4 The work should be planned in a systematic manner so that chase cuttings in the walls, ceilings and floors is minimized. Wherever absolutely essential, the chase shall be cut using chase cutting machines. Chases will not be allowed to be cut using hammer / chisel. The electrical boxes should be fixed in walls simultaneously while raising the brick work. The contractor shall ensure proper co-ordination of various disciplines viz. sanitary & water supply, horticulture & electrical etc.
- 1.5 All the hidden items such as conduits, etc. are to be properly tested before covering.
- 1.6 Samples including brand / quality of materials and fittings to be used in the work shall be got approved from the Engineer-in-Charge, well in advance of actual execution and shall be preserved till the completion of the work.
- 1.7 The contractor, his agents / representative, workman etc. shall strictly observe orders pertaining to fire precautions prevailing in the area.
- 1.8 Contractor(s) shall study the details of site, nature of work to be executed, site constraints etc and satisfy himself about complete characteristics and other parameters at site. However, no claim on the alleged inadequacy or incorrectness of the data supplied by the department shall be entertained.
- 1.9 Contractor shall take all precautionary measures to avoid any damage to adjoining property. All necessary arrangement shall be made at his own cost.
- 1.10 The contractor shall take instructions from the Engineer-in-Charge regarding collection and stacking of materials at any place. No excavated earth or building

Contractor Page 23 of 34 Executive Engineer

rubbish shall be stacked on areas where other buildings, roads, compound wall, services etc are to be constructed.

- 1.11 The contractor shall provide at his own cost suitable measuring arrangements / instruments as may be necessary at site for checking. All such equipments shall be got calibrated in advance from laboratory, approved by the Engineer-in-Charge. Nothing extra shall be payable on this account.
- 1.12 All fittings and accessories should conform to byelaws and municipal body / corporation / Electricity board, where CPWD Specifications are not applicable. The contractor should get the materials (fixtures / fittings) tested by the Municipal Body / Corporation authorities / Electricity board authorities wherever required at his own cost.
- 1.13 Existing drains, pipes, cables, over-head wires, sewer lines, water lines and similar services encountered in the course of execution of work shall be protected against the damage by the contractor at his own expense. The contractor shall not store materials or otherwise occupy any part of the site in a manner likely to hinder the operation of such services. In case temporary supporting/shifting of such services is required to facilitate the work, the same shall be done by the contractor at no extra cost.
- 1.14 In case the existing services are to be shifted permanently, then before dismantling the existing services, alternate/diversion of service lines has to be laid by the contractor so that there is no interruption in use of existing services. The contractor has to plan the alternate suitable route for diversion/shifting of service lines and get the same approved from the Engineer-in-Charge before starting shifting of services. Nothing extra shall be paid except the payment of dismantling and laying of new service lines as per conditions of contract.
- 1.15 With each Running Bill, the details of test carried out shall be submitted by the contractor as per prescribed proforma.
- 1.16 On completion of work, the contractor shall submit at his own cost four prints of "as built" drawings to the Engineer-in-Charge. These drawings shall have the following information.
 - (a) Electrical wiring layout diagram with position of switches, fittings, cabling etc.
 - (b) Run off of all water supply lines with diameters, location of control valves, access panels etc. wherever applicable
- 1.17 In case the contractor fails to supply "as built drawing" aforesaid within 30 days of the date of completion, then the recovery @ Rs.10,000/- each for such set of drawings shall be made from the contractor's final bill.
- 2.0 Unless otherwise specified in the schedule of quantities or CPWD specifications, the rates for respective items shall be all inclusive and apply to the following:
 - a) All labour, material, tools and plants and other inputs involved in the execution of the item.
 - b) Any of the conditions and specifications mentioned in the tender documents.
 - c) Pumping / bailing out surface water / rain water / sub soil water, if necessary for any reason.
 - d) Any legal or financial implications resulting out of disposal of waste, if any.
 - e) Performance test of the entire installation(s) before the work is fmally accepted.

Contractor Page 24 of 34 Executive Engineer

f) All incidental charges for cartage, storage and safe custody of materials brought to site.

3.0 SECRECY

- 3.1 The contractor shall take all steps necessary that all persons employed on any work in connection with the contract have notice that the Indian Official Secrets Act 1923 applies to them & will continue so to apply even after the execution of such works under the contract.
- 3.2 The contract is confidential and must be strictly confirmed to the contractor's own use (except so far as confidential disclosure to sub-contractors or suppliers as necessary) and to the purpose of the contract.
- 3.3 All documents, copies thereof & extracts there from furnished to the contractor shall be returned to the Engineer-in-Charge on the completion of the work / works or the earlier determination of the contract.

4.0 LABOUR AND SECURITY

- 4.1 Contractor should provide his plan for deployment of labour and get it approved from the Engineer-in-Charge.
- 4.2 Contractor has to follow the security requirement of the campus and obtain necessary entry passes for the labour and vehicles and follow security checks at entry / exit gates, restriction on movement of vehicle, restricted timings of working etc. The Department however shall assist the contractor in obtaining such passes for movement of vehicles and labour. No claim whatsoever shall be entertained on account of delay in entry of vehicles and labour including restrictions in working hours, if there is any.
- 4.3 The contractor shall employ only Indian Nationals after verifying their antecedents and loyalty. The contractor shall, on demand submit list of his agents, employees and work people concerned & shall satisfy as to the bonafides of such people.
- 4.4 The contractor & his work people shall observe all relevant rules regarding security promulgated in which work is to be carried out by the Controlling Administrative Authority of the campus/area
- 4.5 The contractor, his representative, workman shall be allowed to enter through specified gates & timing as laid down by the controlling authority. They shall be issued an identity card or an individual pass in accordance with the standing rules & regulations & they should possess the same while working. The contractor shall be responsible for the conduct & actions of his workman, agents / representatives.

5.0 TRANSPORTATION AND OFFICE INFRASTRUCTURE:

In order to complete the work within the scheduled time if the contractor shall be required to do the work in more than one shift and accepted by the department the contractor will provide vehicular facilities to the BSNL site staff to reach the site and their residence at his own cost for their services required beyond the normal office hours. In case the contractor fails to provide the facilities Engineer-in-Charge shall be at liberty to make the arrangement themselves and deduct the respective cost from the contractor's bills.

6.0 PROGRAM CHART: -

6.1 The Contractor shall prepare an integrated program chart for the execution of work, showing clearly all activities from the start of work to completion, with details of manpower, equipment and machinery required for the fulfilment of the program

Contractor Page 25 of 34 Executive Engineer

within the stipulated period or earlier and submit the same for approval of the Engineer-in-Charge within 15 days of the issue of letter of acceptance for the contract.

- 6.2 The work has to be completed in stages as indicated in the **Milestones (Wherever provided)** and the program should be prepared in such a manner to achieve these Milestones as indicated therein or earlier.
- 6.3 The program chart should include the following:
 - a) Descriptive note explaining sequence of various activities.
 - b) Network (PERT / CPM / BAR CHART) which will indicate resources in financial terms, manpower and specialized equipment for every important stage.
 - c) Program for procurement of materials by the contractor.
 - d) Program of procurement of machinery / equipments having adequate capacity, commensurate with the quantum of work to be done within the stipulated period, by the contractor.
- 6.4 If at any time, it appears to the Engineer-in-Charge that the actual progress of work does not conform to the approved program referred above, the contractor shall produce a revised program showing the modifications to the approved program by additional inputs to ensure completion of the work within the stipulated time.
- 6.5 The submission of revised program or approval by the Engineer-in-Charge of such program or the furnishing of such particulars shall not relieve the contractor of any of his duties or responsibilities under the contract. This is without prejudice to the right of Engineer-in-Charge to take action against the contractor as per terms and conditions of the agreement.

Notwithstanding the fact that the contractor will have to pay to the labourers and other staff engaged directly or indirectly on the work according to the provisions of the labour regulations and the agreement entered upon and/or extra amounts for any other reason.

7.0 PROGRESS AND MONITORING OF WORK:

Contractor shall give the Engineer-in-Charge on the 10th day of each month, progress report of the work done during the previous month. Such progress report will include the project progress summary, work progress (planned v/s. actual), PERT chart, milestone status, financial progress status, manpower deployment status, important materials consumed, materials at site at the beginning of the month, materials consumed during the month and the balance quantities at the end of month and progress of the work stating the reasons for shortfall, if any including the steps and measures to be taken for making good the shortfall in the succeeding period. Non submission of aforesaid progress report shall make contractor liable for action under breach of contract conditions. In case of delay in submission of progress report, recovery will be done Rs. 5000/- per week from the Running Account bill, where the decision of EE(E) as to do recovery is final.

8.0 **SAMPLE OF MATERIALS:-**

8.1 All materials and fittings brought by the contractor to the site for use shall conform to the samples approved by the Engineer-in-Charge which shall be preserved till the completion of the work. If a particular brand of material is specified in the item of work in Schedule of Quantity, the same shall be used after getting the same approved from Engineer-in-Charge. Wherever brand / quality of material is not specified in the item of work, the contractor shall submit the samples as per **List of Preferred Makes**

Contractor Page 26 of 34 Executive Engineer

for approval of Engineer-in-Charge. For all other items, ISI Marked materials and fittings shall be used with the approval of Engineer-in-Charge. Wherever 1S1 Marked material / fittings are not available, the contractor shall submit samples of materials / fittings manufactured by firms of repute conforming to relevant Specifications or IS codes for the approval of Engineer-in-Charge.

- 8.2 To avoid delay, contractor should submit samples as stated above well in advance so as to give timely orders for procurement. If any material, even though approved by Engineer--in-Charge is found defective or not conforming to specifications shall be replaced / removed by the contractor at his own risk & cost.
- 8.3. **BIS** marked materials except otherwise specified shall also be subjected to quality test besides testing of other materials as per the specifications described for the item/material. Wherever BIS marked materials are brought to the site of work, the contractor shall, furnish manufacturer's test certificate or test certificate from approved testing laboratory to establish that the material procured by the contractor for incorporation in the work satisfies the provisions of specifications relevant to the material and / or the work done.
- 8.4 For certain items, if tests are neither mentioned in the CPWD Specifications & BIS, then tests shall be carried out as per decision of Engineer-in-Charge.

9. Coordination at site:

At the site of work, as more than one agency may be working, full cooperation shall be extended to other agencies during progress of work. Further, work shall be carried in such a way so that it may not cause abnormal noise and hindrance to the officers of the department engaged in erection as well as doing normal routine work.

10. Joint Inspection;

Since the work is to be executed for the third party, A joint inspection report will be made by the BSNL representative and representative of the firm & representative of client/user regarding the functioning of the system, defects and remedial action required in time schedule for the rectification/remedial action. Agency is bound to attend to the defects/discrepancies in timely manner, failing which Engineer in charge is fully empowered to set right the defects with reasonable notice.

Contractor Page 27 of 34 Executive Engineer

Contractor Page 28 of 34 Executive Engineer

LIST OF APPROVED MAKES

S No.	Item	Makes
1	Engine	Ashok Leyland /Cummins/ Cater pillar /KOEL/ Volvo Penta
		/ Mahindra & Mahindra (up to 200 KVA) /Escorts (up to 30
		KVA)/ Eicher (up to 35 KVA)
2	Alternator(Brushless)	Crompton Greaves (AL. series) / KEC / Leroy Somer /
		Stamford/Jyoti Ltd
3	Battery (Lead Acid /	Amara Raja / AMCO / Farukawa / Hitachi
	Mntc. Free)	/ Exide/ Prestolite / Standard
4	HV Switchgear (Vacuum	Biecco Lawrie / Crompton / Kirloskar / MEI / Jyoti Ltd
	Circuit Breaker/SF6)	
5	Transformer (Oil filled	ABB / Schneider Electric /Andrew Yule /
	/ Dry type)	Bharat Bijlee / Crompton / EMCO /Kirloskar / Siemens
	a) Above 400 KVA	
	b) Up to 400 KVA	In addition to above makes, Uttam/ Patson /Rajasthan
		Transformer and Switchgear
6	Air Circuit Breaker	L&T/ Schneider Electric / Siemens
7	MCCB(Ics=Icu)	L&T/ Schneider Electric / Siemens
8	SDF units	L&T/ Schneider Electric / Siemens/HPL/Havells
9	Power Contactors	L&T/ Schneider Electric / Siemens/ Lakshmi(LECS)
10	Change Over Switch	HPL / Havells / H-H Elcon
11	Intelligent APFC Relay	L&T/EPCOS(Siemens)/ Schneider Electric
		/ Neptune Ducati/Syntron/ABB
12	Bus Bar Trunking/	Moeller/L&T/Schneider Electric/ABB/ Legrand /Zeta
	Sandwiched Bus Duct	
13	Power Capacitors	L&T/EPCOS(Siemens)/ABB/Crompton/
	(MPP/APP)	Schneider Electric / Neptune Ducati
14	Digital/ KWHr meter	Schneider Electric/ AE/ Digitron / IMP/Meco / Rishabh
		/Universal/HPL/L&T/ABB/Yokins
15	Cold shrink HT/LT	Denson / 3M(M-Seal)/ Raychem
	Cable Joint	
16	Rubber Matting	ISI mark
17	MCB/ Isolator	Crompton / Havells / Indokopp / MDS
	/ELCB/RCCB/	Legrand / L&T / Schneider Electric/
1.0	Distribution Board	Siemens / Standard/ABB/HPL
18	MS/ PVC Conduit	ISI mark
19	Cable Tray	MEM/Bharti/Ratan/Slotco/Profab
20	HT/LT Cables	ISI mark
21	PVC insulated copper	ISI mark
22	conductor wire	Assemble / DE / Decemble / Detlike: / Consider / Lett / Williams
22	Centrifugal Pump	Amrut / BE / Beacon / Batliboi /Crompton / Jyoti / Kirloskar
22	Cubmaraible Duran	/ KSB / Mather & platt / WASP/Grundfos
23	Submersible Pump	Crompton/Amrut / BE / Calama / Kirloskar / KSB
24	Motors	ABB/ Bharat Bijlee / Crompton Greaves /

Contractor Page 29 of 34 Executive Engineer

		Schneider Electric / HBB / KEC / Siemens/Jyoti Ltd
25	Fresh Air Fans	GE / Khaitan/Almonard/Crompton
26	Starter	ABB / BCH / Schneider Electric / L&T / Siemens /
27	Single Phase Preventer	L&T / Minilec / Siemens / Zerotrip
28	GI/MS Pipe	ATC / ATL / BST / GSI / ITC / ITS / IIA /
		JST / Jindal /TTA / Tata/Zenith
29	Foot Valve	ISI mark
30	Gate Valve	Advance/Audco/Johnson Controls / Zoloto/ Annapurna /
		Fountain /Kirloskar / Leader / Sant / Trishul
31	Compressors	Carrier/Emerson copeland/York/Danfoss
		(for chillers only)
32	Resin Bonded Glasswool	Fibre Glass / Pilkingston / UP Twiga
33	Expanded Polystyrene	BASF(India) Ltd.
34	Gauge	Feibig / H.Guru / Pricol
35	Controls	FLICA / Honeywell / Indfoss / Penn- Danfoss / Ranco /
		Ranutrol / Sporland
36	Fine Filters	Anfiltra Effluent / ARW / Athlete/ Airtake / Dyna /
		Kirsloskar/ Puromatic/ Purafill/ Purolator / Tenacity
37	GI Sheet	HSU Jindal / National / Nippon Denro /
		Sail / Tata
38	Heat Detector	Appollo / Chemtron/ Edward / Fenwal/ Hochiki / Nitton
		/System Sensor/ Wormald/Honeywell Essar/Notifier
39	Ionization Detector	Appollo / Cerebrus / Edward/ /Fenwal / Hochiki / Nitton /
		System Sensor /Wormald
40	Photo Electric Smoke	Appollo / Cerebrus / Edward / Fenwal/ Hochiki / Nitton /
	Detector	Wormald /System Sensor
41	Fire Panel	Agni Instruments / Agni Devices/ Aruna Agencies / Carmel
	(Microprocessor	Sensor / Ravel Elect. / Honeywell Essar / Notifier / Navin
	based)	Systems
42	Sprinkler/ Hose Reel &Hose	ISI mark
	Pipe	
43	Fire Extinguisher	ISI mark
44	Lift	OTIS, Kone, Mitsubishi , Schindler, Johnson, Thyssenkrupp
		Elevator(India)

Contractor Page 30 of 34 Executive Engineer

COMPLIANCE STATEMENT

We full manner with all the General, Commercial, Technic Tender Document for the work of "Shifting and re-In OCB/NIB at 1st floor of TE KK Nagar Bldg, Chennai. (and deviation.	cal, Operating, financial conditions of the stallation of the 3 Nos of PAC units for
For and on behalf of (Name of Firm)	
(Seal of the contractor /Company /Firm)	
(Signature of contractor/Authorized Signatory)	
(Postal address)	Dated

Contractor Page 31 of 34 Executive Engineer

Shifting and re-Installation of the 3 Nos of PAC units for Name of the work :-OCB/NIB at 1st floor of TE KK Nagar Bldg, Chennai. (From Chrompet)

PROFORMA OF SCHEDULES

(Operative Schedules to be supplied separately to each intending tenderer)

SCHEDULE 'A'

Schedule of quantities: Attached

SCHEDULE 'B'

Schedule of materials to be issued to the Nil

bidder:

SCHEDULE 'C'

Tools and plants to be hired to the Nil

bidder:

SCHEDULE 'D'

Extra schedule for specific Nil

requirements/documents for the work, if any:

SCHEDULE 'E'

Schedule of components of Materials, Labour etc. Nil

for escalation:

SCHEDULE 'F'

Reference to General Conditions of contract:

Name of work:	
Estimated cost of work:	As nor NIT notification page
Earnest money:	As per NIT notification page
Security Deposit and performance Guarantee	

General Rules & Directions: Officer inviting Executive Engineer (E) Electrical Division-I, Chennai

tender:

Definitions:

2(v) Engineer-in-Charge Executive Engineer (E)

Electrical Division-I, Chennai

2(vi) Accepting Authority Executive Engineer (E)

Electrical Division-I, Chennai

Percentage on cost of materials and 2(x)

labour to cover all over heads and profits 10% (TEN)

CLAUSE 5

Time allowed for execution One Month

Authority to give fair and reasonable extension

Executive Engineer (E) of time for completion of work:

Executive Engineer (E) Competent Authority for deciding reduced rates:

Clause 25

Competent authority for conciliation: Executive Engineer (E)

Contractor Page 32 of 34 **Executive Engineer**

BSNL EW-8

Bharat Sanchar Nigam Limited Electrical Wing

Electrical Division: **ED-I, Chennai** Sub Division: **ESD-III, Chennai**

- 1. I/we have read and examined the notice inviting tender, schedule, specifications applicable, Drawings & Designs, General Rules and Directions, Conditions of Contract, clauses of contract, special conditions, Schedule of Rates and other documents and Rules referred to in the conditions of contract and all other contents in the tender document for the work.
- 2. I/We hereby tender for the execution of the work specified for BSNL within the time specified, schedule of quantities and in accordance in all respects with the specifications, designs, drawings and instructions and other documents and Rules referred to in the conditions of contract and all other contents in the tender document for the work.
- 3. I/We agree to keep the tender open for ninety (90) days from the due date of submission thereof and not to make any modifications in its terms and conditions.
- 4. If I/We, fail to commence the work specified, I/We agree that the said BSNL shall without prejudice to any other right or remedy, be at liberty to forfeit the said earnest money absolutely and the same may at the option of the competent authority on behalf of BSNL be recovered without prejudice to any other right or remedy available in law out of the deposit in so far as the same may extend in terms of the said bond and in the event of deficiency out of any other money due to me/us under this contract or otherwise.
- 5. Should this tender be accepted, I/We agree to execute all the works referred to in the tender documents upon the terms and conditions contained or referred to therein and to carry out such deviations as may be ordered upto maximum of percentage mentioned in clause 12.3 of the tender form and those in excess of that limit at rates to be determined in accordance with provisions contained in clause 12.2.
- 6. I/we agree to furnish to BSNL, Deposit at Call receipt/FDR/ Bank guarantee of a Nationalized/ Scheduled Bank for an amount equal to 5% of the contract value in a standard format within two weeks from the date of issue of award letter. I/We agree to keep the performance bank guarantee valid as per the BSNL terms and conditions.
- 7. I/We hereby declare that I/We shall treat the tender documents drawings and other records connected with the work as secret/confidential documents and shall not communicate information/derived therefrom to any person other than to whom I/We am/are authorized to communicate the same or use the information in any manner prejudicial to the safety or interest of BSNL.

Contractor Page 33 of 34 Executive Engineer

Signature of Witness (required in the case of bidder's thumb impression is given by the bidder in place of signature) Occupation of Witness:	(Signature of bidder) (Name & Postal address)
	Seal of Bidder
	Date:
Accortons	o of Tondon
Acceptance	<u>e of Tender</u>
The above tender (as modified by you as pr	rovided in the letters mentioned hereunder) is
accepted by me for and on behalf of BSN	L for a sum of Rs
(Rupees)
The letters referred to below shall form part of	this contract Agreement.
a)	
b)	
	For & on behalf of BSNL
Dated	
	Signature :
De	signation:

Contractor Page 34 of 34 Executive Engineer